

supply.

SANS 60529	Degrees of protection provided by enclosures (IP Code)
SANS 61869-2	Instrument Transformers Part 2: Additional requirements for current transformers.
NRS 082	Recommended maintenance policy for electricity networks.

PS3.2.25 MAINTENANCE OF MEDIUM VOLTAGE ELECTRICAL RETICULATION CATEGORIES

The Medium Voltage maintenance tender consist of six categories. Contractors able to submit bids per category and field of expertise. Below listed categories –

- Category A - Maintenance of medium voltage switchgear within protected substations.
- Category B - Maintenance of medium voltage ring main units, switchgear, and metering units.

PS3.2.26 SCHEDULED WORK

All scheduled work shall be discussed with the Contractor in advance and all the dates to be agreed on shall be binding to both parties unless it is impossible to adhere to. Any changes to the schedule shall be kept at a minimum and immediately communicated to all stakeholders.

Continuous failure by the contractor to perform functions as stipulated in the tender document, the Breede Valley Municipality reserves the right to initiate default proceeding and may terminate the contract.

PS3.2.27 PORTFOLIO OF EVIDENCE

Successful tenderer to supply photographic evidence in electronic (PDF) format of the work at the following stages:

Before the work starts two stages while in progress as instructed by the Employers agent e.g. Photos of equipment with defects or signs of deterioration. Inspection sheets.

PS3.2.28 MAINTENANCE MANUALS, VIDEOS AND TASK LISTS

The Contractor shall provide and append maintenance task lists and quality plan, including specific maintenance instructions, evaluation forms maintenance revisions from the manufacturer and safety notices from the manufacturer for the below mentioned Switchgear.